

GMA200-MT

Customer:

Order #:



Relay configuration

Date:

Relay	Designation (*1) (max. 20 characters)	Functionality (*2)	Mode of operation (*3)	Voting (*4)	Measuring points (*5)															
					01	02	03	04	05	06	07	08	09	10	11	12	13	14	15	16
01																				
02																				
03																				
04																				
05																				
06																				
07																				
08																				

About (*1) Designation: free text field for describing the relay function, e.g.: **Pre-alarm, main alarm, service, fault, external horn, internal horn, valve X, fan Y**

About (*2) Functionality: describes the condition when relay switches, e.g.: **AL1=Alarm1, AL2=Alarm2, AL3=Alarm3, SRV-TRM=Maintenance transmitter, SRV-GMA=Maintenance GMA, FLT-TRM=Fault transmitter, FLT-GMA=Fault GMA, RESET=Horn acknowledgement during an active alarm**

About (*3) Mode of operation: Mode of operation of the relay coil **open-circuit** or **closed-circuit**

About (*4) Voting: **OFF**=no voting function; **2, 3, 4 of X** = At least 4 measuring points must meet the condition described under "Functionality" for switching.

About (*5) Measuring points: **X** marks the measuring points which are relevant for the respective relay.